



The Public Health and Safety Organization

NSF Product and Service Listings

These NSF Official Listings are current as of **Wednesday, September 3, 2025** at 12:15 a.m. Eastern Time. Please [contact NSF](#) to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information:

<http://info.nsf.org/Certified/PwsChemicals/Listings.asp?Company=Co447630&Standard=060&>

NSF/ANSI/CAN 60 Drinking Water Treatment Chemicals - Health Effects

BlueGreen Water Technologies Ltd.

16 HaMiktsot Boulevard

Modi'in-Maccabim-Re'ut

7178096

Israel

972 3 64 27111

[Visit this company's website](#)

(<http://bluegreenwatertech.com>).

Facility : Fountain Inn, SC

Aluminum Sulfate[AL]

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Lake Guard Dew	Coagulation & Flocculation	92mg/L
Lake Guard® Dew	Coagulation & Flocculation	92mg/L

[AL] Based on an evaluation of health effects data, the level of aluminum in the finished drinking water shall not exceed 2 mg/L.

Copper Sulfate[1]

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Lake Guard Blue	Algicide	4mg/L
Lake Guard® Blue	Algicide	4mg/L
Lake Guard™ Blue	Algicide	4mg/L

[1] The use of copper sulfate as an algicide may increase the amount of copper present in the finished drinking water. Following use of this product, the finished drinking water should be monitored to ensure that levels of copper do not exceed regulatory requirements.

Sodium Percarbonate

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Lake Guard Oxy	Algicide	33mg/L
Lake Guard ® Oxy	Algicide	33mg/L
Lake Guard™ Oxy	Algicide	33mg/L

Facility : Ohio, United States

Aluminum Sulfate[AL]

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Lake Guard Dew	Coagulation & Flocculation	92mg/L
Lake Guard® Dew	Coagulation & Flocculation	92mg/L

[AL] Based on an evaluation of health effects data, the level of aluminum in the finished drinking water shall not exceed 2 mg/L.

Copper Sulfate[CP]

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Lake Guard Blue	Algicide	4mg/L
Lake Guard® Blue	Algicide	4mg/L
Lake Guard™ Blue	Algicide	4mg/L

[CP] The finished drinking water shall be monitored to ensure that levels of copper do not exceed 1.3 mg/L.

Sodium Percarbonate

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Lake Guard OXY	Algicide	33mg/L

Facility : Kempton Park, South Africa

Sodium Percarbonate

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Lake Guard™ OXY	Algicide	33mg/L

Number of matching Manufacturers is 1

Number of matching Products is 15

Processing time was 0 seconds